

9/27

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI - 110001**

No.F6/DFS/MS/SZ/2024/ 485

Dated: 30/08/2024

To

The President/Secretary,  
The Interstate CGHS Ltd.  
Plot No. 06B, Sector - 23, Dwarka,  
New Delhi - 110075

**Subject: - Renewal of Fire Safety Certificate in r/o The Interstate CGHS Ltd. Located at Plot No. 06B, Sector - 23, Dwarka, New Delhi - 110075.**

Sir,

Please refer to your letter No. nil dated 22/07/2024 on the subject mentioned above. In this connection it is to inform you that the premises was visited by the officer concerned from this department on 20/08/2024 in the presence of Sh. Y K Panda (Manager) from fire safety point of view.

During the course of inspection following shortcomings are observed:

1. Six meter wide internal road around the building found blocked/encroached
2. Exit signage's found removed at some places
3. Communication system in lift car found removed
4. Both the Blocks are connected at 7<sup>th</sup> floor but the passage found obstructed. The Passage must be clear from any obstruction and free from lock & keys.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered. The applicant is directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully

(Atul Garg)  
Director  
Delhi Fire Service

Copy to: - The Joint Director (Building) DDA, Vikas Sadan, INA, Delhi-110023.