

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/EH/2024/SZ/ 360
To

Dated 29/08/2024

The Joint Commissioner of Police
(Lic/Branch) 1st Floor PS Defence Colony,
New Delhi 110049

Sub: -Regarding issuance of fire safety certificate in r/o M/s Brims Coffee House located at HS-7, Second Floor, Kailash Colony Market, New Delhi 110048.

Sir,

This has reference to with **MHA Portal 2024073111967 dated 31/07/2024** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 22.08.2024 in the presence of Mr. Khalid (Manager) to verify the fire safety measures installed in the building and observed that restaurant running at 2nd Floor only. During inspection, following points were observed:

1. There are two exit doors having width of 1.50 mtr & 1.35 mtr against the required width of 1.50 mtr each.
2. A kitchen is running in the staircase lobby, which need to be removed.

In view of above observation, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall not be allowed in the interest of public safety. The liability of any loss of life and property in case of any eventuality / misshape shall be lies with the owner/ occupier of the building.

Yours faithfully

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

dlr w