

5
5
5

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001**

NO. F6/DFS/MS/CGHS/SZ/2024/ 481

DATED: 29/08/2024

To,

The Authorized Signatory,
M/s External Affairs Employees CGHS Ltd.
Plot No. 24, Sector-04,
Dwarka, New Delhi - 110078.

Subject: - Renewal of Fire safety Certificate from fire safety & means of escape point of view in r/o M/s External Affairs Employees CGHS Ltd. Located at Plot No. 24, Sector-04, Dwarka, New Delhi - 110078..

Sir,

This is in reference to your letter no. Email Dated -18/07/2024 on the subject cited above. In this connection it is to inform to you that the above said premises was inspected by the officer concerned of this department on 16/08/2024 in the presence of Sh. Harpal Singh (M.C. Member) Sh. Chander R Sen(Secretary)


During the course of inspection followings shortcoming have been observed:-

1. Six meter wide internal road found not clear/ encroached.
2. During the visit hose reel hoses were operated at randomly selected two places. The hose reel hose found leaking/ nonfunctional.
3. Exit signage found removed at some places.
4. Branches & hoses found missing at some places/ floors.

You are requested to comply the abovementioned shortcomings under intimation to this department.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,


(Atul Garg)
(Director)
Delhi Fire Service

Copy to:-

1. The Joint Director(Big.), DDA, Vikas Sadan, INA, New Delhi.