

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001

No.F6/DFS/MS/SZ/2024/ 476

Dated: 29/08/2024

To

Ms, Neeru Naruloa (Managing Director),
Hahnemann Pharmaceuticals Pvt. Ltd.
A-7, Naraina Industrial Area, Phase-1,
New Delhi - 110028

**Subject: - Renewal of Fire Safety Certificate in r/o Hahnemann Pharmaceuticals Pvt. Ltd.
Located at A-7, Naraina Industrial Area, Phase-1, New Delhi - 110028.**

Sir,

Please refer to your letter No. nil, dated 19/07/2024 on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by the officer concerned from this department on 17/08/2024 in the presence of Ms. Suman (Receptionist) from fire safety point of view.

During the course of inspection following shortcomings are observed:

1. Exits/ Staircase found obstructed/ partially blocked.
2. Exit signages found removed at some places.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered. The applicant is directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully


(Anil Garg)
Director
Delhi Fire Service

Copy to: - The Executive Engineer (Building), MCD, Karol Bagh Zone, Anand Parbat, New Delhi.