

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F6/DFS/MS/2024/SZ/475  
To

Dated: 29/08/2024

M/s Kiwanis Bhawan  
Kiwanis Club of New Delhi  
B-35, Qutab Institutional Area,  
New Delhi-110016

Sub.: - Regarding issuance of Fire Safety Certificate in r/o M/s Kiwanis Bhawan (Kiwanis Club of New Delhi) located at B-35, Qutab Institutional Area, New Delhi-110016

Sir,

This has reference to your letter, received through Email dated 07/08/2024 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 20.08.2024 in the presence of Ms. Sweta (Admin officer) to check the compliance of fire safety arrangements installed in the building from fire safety point of view and following shortcomings/ observations made are as under:

1. The sprinkler system in basement shall also be extended in the left out area.
2. The Exit Signage's found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

  
(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE  
