

C/80

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI - 110001**

No.F6/DFS/MS/SZ/2024/ 479

Dated: 29/08/2024

To

The President/Secretary,  
Media CGHS Ltd.  
Plot No. 18A, Sector - 07, Dwarka,  
New Delhi - 110075

**Subject: - Renewal of Fire Safety Certificate in r/o Media CGHS Ltd. Located at Plot No. 18A, Sector - 07, Dwarka, New Delhi - 110075.**

Sir,

Please refer to your letter No. nil dated 29/07/2024 on the subject mentioned above. In this connection it is to inform you that the premises was visited by the officer concerned from this department on 22/08/2024 in the presence of Sh. Ravikant from fire safety point of view.

During the course of inspection following shortcomings are observed:

1. Six meter wide internal road around the building found blocked/encroached
2. At least two fire extinguishers required near hose reel/down comer *at each floor.*
3. MOEFA & PA system found nonfunctional
4. Hose reel hose & hydrants found nonfunctional.
5. Hoses & branches found missing at some places
6. Terrace pumps of capacity 900 lpm found nonfunctional.
7. Exit signage's found removed at some places

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered. The applicant is directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully

*(Signature)*  
(Anil Garg)  
Director  
Delhi Fire Service  
*ok* *23/8/24*

Copy to: - The Joint Director (Building) DDA, Vikas Sadan, INA, Delhi-110023.