



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/2024/SZ/ 486

Dated: 30/08/2024

To

Sh. Debasis Routray,  
Manager, Odisha Bhawan,  
O/o The Chief Resident Commissioner,  
Odisha Niwas, 4, Bordoloi Marg,  
Chanakya Puri, New Delhi-110021

**Sub: Regarding issuance of Fire Safety Certificate in r/o "Odisha Bhawan" located at 1, Niti Marg, Chanakya Puri, New Delhi-110021**

Sir,

This has reference to email & attachment received on dated 08/08/2024. In this connection, the said premise was visited by the officers concerned of this department on dated 21/08/2024 in the presence of Mr. S.S. Rawat (Electrical Contractor) to verify the status of fire safety arrangements. During the inspection, the shortcomings observed are as below.

1. Fire Check Door shall be provided to segregate basement & ground floor.
2. First Aid hose-reel found non-functional.
3. Manually operated fire alarm system shall be provided at some places as pointed out.
4. Terrace level fire pump was not on auto mode.
5. Exit signages found removed at some locations as pointed out.
6. Fire Check Door to be provided in the kitchen area and alternate exit door shall open outwards.

In view of the above shortcomings, the application for issuance of fire safety certificate is rejected. You are advised to rectify the above shortcomings under intimation to this department for further action in the matter.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

Copy to: -

1. The Chief Architect, Department of Architecture & Enviorms, N.D.M.C. Palika Kendra, New Delhi-110001