disz

## GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI

No. F6/DFS/MS/EH/WZ/2024/ 372

Dated: 02 / 09 /2024

To,

The Joint Commissioner of Police, Licensing Unit, 1<sup>st</sup> floor, Police Station, Defence Colony, New Delhi. addlcp.lic-dl@nic.in

Subject: Regarding renewal of NOC from fire safety point of view in respect of M/s Bercos

(A unit of Bercos Melody House) located at, Property No. F-90, First Floor &

Second Floor, Vishal Enclave, Rajouri Garden, New Delhi-110027.

Sir,

Please refer to your online application no. Online Application ID No. 2024072411525 dated 02/08/2024, on the subject cited above. In this connection, it is to inform you that the premises was inspected by officer concerned of this department on 22/08/2024 in the presence of Sh. Mahesh Kumar (Rest. Manager) to see the functioning of fire safety equipments provided in the building.

During inspection, it has been observed that the above restaurant is running at 1<sup>st</sup> & 2<sup>nd</sup> floor in a Building comprised of basement, Ground + 02 Upper floors. Fire safety arrangements such as Fire Extinguishers, Hose Reel Hose, Internal Hydrant, MOEFA, Pumping Arrangements, etc provided. However the following shortcomings were observed.

- 1. Second exit passing through kitchen. It is not allowed. Kitchen wall is made of glass it should be enclosed by Fire rated glass or brick wall.
- 2. Internal staircase from 1<sup>st</sup> to 2<sup>nd</sup> floor is open. It should be segregated by FCD.
- 3. First Aid Hose Reels & Internal Hydrant is provided but not functional.
- 4. MOEFA is provided but not functional.
- 5. Terrace level pump capacity of 450 lpm is provided against requirement of 900 lpm.
- Overhead water storage tank capacity of 5,000ltr provided against requirement of 10,000ltr.
- 7. Exit Signage's found removed.

In view of above Shortcomings, the application for renewal of Fire safety Certificate is not considered at this stage & rejected. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provided all necessary fire arrangements.

Copy to: -

- 1. The DHO, MCD, West Zone, Shivaji Enclave, Raja Garden, New Delhi-110027.(dhowest zone@gmail.com).To -(To take necessary action till fire safety arrangements are provided)
- 2. The Commissioner, Excise, Entertainment & Luxury Tax Department, Govt. of NCT of Delhi, L & N Block, Vikas Bhawan, I.P. Estate, New Delhi- 110002.- (For taking necessary action)
- 3. The Owner/Occupier, M/s Bercos (A unit of Bercos Melody House) located at, Property No. F-90, First Floor & Second Floor, Vishal Enclave, Rajouri Garden, New Delhi-110027.