

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/GH/2024/SZ/ 492
To

Dated: 02/09/2024

The Authored Signatory,
Commercial Space / PD Area
3rd Floor, 5th Level, NSIC Okhla Metro Station,
Okhla Industrial Area, New Delhi 110020

Sub: Regarding issuance of FSC in r/o M/s Commercial Space / PD Area at 3rd Floor, 5th Level, NSIC, Okhla Metro Station, Okhla Industrial Area, New Delhi 110020.

Sir,

This is in reference with letter received through outdoor diary no 3435 dated 26/07/2024 on the subject cited above. In this connection, the premises have been inspected by officer concerned of this department on 27.08.2024 in the presence of Mr. Akshat Goel to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

1. There are 04 staircases communicated from ground floor to 5th floor out of these 04 staircases, 03 staircases found under lock and key / closed by DMRC only, one staircase is available for fire escape in case of emergency.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATEL GARG)
DIRECTOR

DELHI FIRE SERVICE