



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2024/School/ 581

Dated: 03/09/2024

To

The Manager
First Mark Public School at B- 119,
60 Foota Road, Baba Colony, Burari, Delhi-84.

Sub: - Regarding grant of fire safety certificate in r/o First Mark Public School located at B- 119,
60 Foota Road, Baba Colony, Burari, Delhi-110084.

Sir,

Please refer to your letter no- nil dated 05.08.2024 on the subject cited above. In this connection this is to inform you that the above mentioned school premises was inspected by the officer concerned of this department on 21.08.2024 in the presence of Sh. Satya Prakash (Manager) was also present at site to check the existing fire safety measures & means of escape measures. During inspection it has been observed that the school premises is comprised of 02 blocks, one block comprised of ground floor & one block comprised of ground & 02 upper floors but school is running at ground & first floor only, 2nd floor used for residence purpose. The observations/ shortcomings made are as under:-

1. There is only one staircase provided width of 90cm against the requirement of 1.50m or and additional staircase 75cm.
2. The class rooms all door size is provided 80cm against the requirement of 01m.
3. As built plan of the school duly signed by registered architect & owner shall also be submitted.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school premises is at your own risk & responsibility.

Yours faithfully

(Anul Garg)

Director

Ph: 011-23414000

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.