



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**



No. F6/DFS/MS/2024/CC/ 283

Dated: 02/09/2024

To

The Authorized Signatory  
 Plot No- 28/6, Block-29, Nagia Park  
 Chowk, Shakti Nagar, Delhi-110007.

**Sub:** - Regarding issuance of fire safety certificate in r/o Frankfinn Aviation Service (P) Limited (Institute) Plot No- 28/6, Block-29, Nagia Park Chowk, Shakti Nagar, Delhi-110007.

Sir,

Please refer to your letter no. Nil dated 01.08.2024 received in this department vide outdoor dairy no-4992 dated 06.08.2024 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 16.08.2024 in the presence of Smt. Swati Aggarwal (Manager Head) was also present at site to check the existing fire safety measures & means of escape measures. During inspection it has been observed that the building is comprised of ground & 03 upper floors but (institute running at 2<sup>nd</sup> & 3<sup>rd</sup> floor only). The observations/ shortcomings made are as under:-

1. There is 02 nos. of staircases provided having width of 1.50m & 90cm against the requirement of 1.50m each from ground to terrace level.
2. The width of class room doors is 90cm against the requirement of 1.20m
3. Hose reel hose is provided but not functional.
4. Terrace level fire pump capacity of 450lpm is provided but not functional.
5. Standby power supply is not provided.
6. One temporary tin shed room constructed at terrace level needs to be removed.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the abovementioned shortcomings under intimation to this department; till such time running of building (Institute) is at your own risk & responsibility.

Yours faithfully

(Anil Garg)

Director

Ph:-011-23414000

*[Handwritten signature]*  
 29/8