



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



dos

No. F6/DFS/MS/2024/School/ 585

Dated: 03/09/2024

To

The Principal
Gargi Global School
At Khasra No-120/20, Street No-5, B-Block
West Kamal Vihar, Burari, Delhi-110084.

Sub: - Regarding grant of fire safety certificate in r/o Gargi Global School located at Khasra No-120/20, Street No-5, B-Block West Kamal Vihar, Burari, Delhi-110084.


Sir,

Please refer to your letter no-nil dated 01.08.2024 received in this department vide outdoor dairy no-4856 dated 02.08.2024 on the subject cited above. In this connection this is to inform you that the above mentioned school premises was inspected by the officer concerned of this department on 12.08.2024 in the presence of Sh. Geeta Ram (Principal) was also present at site to check the existing fire safety measures & means of escape measures. During inspection it has been observed that the school building is comprised of ground & first floor only. The observations/ shortcomings made are as under:-

1. There is only one staircase provided width of 90cm against the requirement of 1.50m or and additional staircase 75cm.
2. The class rooms door size is provided 90cm against the requirement of 01m.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school building is at your own risk & responsibility.

Yours faithfully


(Anil Garg)
Director
Ph:-011-23414000
g/c

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.

1/1
31/8