

a-57

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI - 110001**

No.F6/DFS/MS/SZ/2024/ GH | 542

Dated: 02 10 9 / 2024

To

The Addl. Commissioner of Police,  
Licensing Unit 1st Floor,  
P.S Defence Colony,  
New Delhi-110049

**Subject: - Renewal of Fire Safety Certificate in r/o M/s Hotel Hill Palace Located at 14A/32, WEA, Karol Bagh, New Delhi-110005.**

Sir,

Please refer to online application No. 2024080712330, dated 07/08/2024 on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by the officer concerned from this department on 24/08/2024 in the presence of Sh. Ranjeet Singh Negi (Manager) from fire safety point of view.

During the course of inspection following shortcomings are observed:

1. Ventilation system not provided in common area.
2. CO Detectors found removed.
3. Hose reel hose found nonfunctional.
4. Terrace pump of capacity 900 lpm found nonfunctional & main valve found closed at terrace level.
5. Basement found closed could not be inspected.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered. The applicant is directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully

(Atul Garg)  
Director

Delhi Fire Service

Copy to: -

1. The Executive Engineer (Building), MCD, Civic Centre, Minto Road, New Delhi for information w.r.t. the use of the basement.
2. The Manager, M/s Hotel Hill Palace Located at 14A/32, WEA, Karol Bagh, New Delhi-110005.