

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

C/16



No: F.6/DFS/MS/2024/WZ/ School | 575

Dated: 03/09/2024

To,

The Principal,
Indian Convent School,
CU- Block, Pitampura,
Delhi-110034.

Sub: - Regarding renewal of Fire Safety Certificate in r/o Indian Convent School
located at CU Block, Pitampura, Delhi- 110034.

Sir,

This has reference to your e mail id dated 01/08/2024 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 09.08.2024 to see the compliance of the requisite fire safety measures. Smt. Neena Lamba (Head Mistress) was present at the time of inspection.

During the course of inspection it was observed that the building comprised of Ground and First floor. Your request for renewal of FSC is rejected as the following shortcomings were observed:-

1. Temporary rooms found constructed under the staircase has to be removed.
2. Electric panel under the staircase has to be removed to a safer place.

You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for renewal of Fire Safety Certificate.

Yours Faithfully

(Atul Gang)
Director

Ph. 011-23414000

Copy to :-

1. Director of Education, Govt. Of NCT of Delhi, Old Secretariat, New Delhi.