

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/EH/2024/SZ/366

Dated 30/08/2024

To

The Joint Commissioner of Police / Licensing,  
1<sup>st</sup> floor, Police Station, Defence Colony,  
New Delhi- 110049

Sub: - Regarding issuance of fire safety certificate in r/o **M/s Juggernaut** (A Unit of Gardens of Earth Pvt. Ltd.), HS-16, Kailash Colony, New Delhi-110048.

Sir,

This has reference to with **MHA Portal ID 2024080612279 Dated: 06.08.2024** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 22.08.2024 in the presence of Mr. Shyam to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

- 1 There are only one staircase width of 1.0m against the requirement of two staircase having width of 1.50 mtr each.
- 2 There are two exit door having width of 2.0 mtr & 1.0 mtr provided against the required width of 1.50 mtr each.
- 3 First aid hose reel found removed.
- 4 Automatic Detector system not provided
- 5 MOEFA system not provided.
- 6 Internal hydrant not provided.
- 7 Main electrical fire pump capacity of 2280 lpm & Diesel pumps capacity of 2280 lpm and jockey pump capacity 180 lpm not provided. Terrace level fire fighting pump capacity 450 lpm not provided.
- 8 Underground tank capacity 1, 00,000 ltrs not provided.
- 9 Overhead water storage tank capacity 10,000 ltrs not provided.
- 10 Exit Signage not provided in the building.
- 11 Standby power supply not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE