

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**



No. F6/DFS/MS/WZ/2024/ 493  
To,

Dated: 02/09/2024

The Authorized Signatory,  
Movie Time Cinemas Pvt. Ltd.,  
KP Block, Community Center,  
Pitampura, Delhi-110034.

**Sub: - Inspection report in r/o M/s Movie Times Cineplex Pvt. Ltd. located at KP Block, Community Centre, Pitampura, Delhi- 110034.**

Sir,

This has reference to your application no. nil received through outdoor diary number 5178 dated 12/08/2024 on the subject cited above. In this connection, it is to inform you that the inspection of above assembly building has been carried out by officer concerned of this department on 24/08/2024 to see the compliance of the requisite fire safety measures. Sh. Lokesh Sharma (Manager) was present at the time of inspection.

During the course of inspection it was observed that the cinema hall is running in (Audi 1-3) at 1<sup>st</sup> floor and projector room at 2<sup>nd</sup> floor in a building comprised of Lower Basement, Upper Basement, Ground and four upper floors. Your request for renewal of FSC is rejected as the following shortcomings were observed:

1. Exit doors found locked at some places.
2. Smoke management system of Audi-3 found provided but not functional.
3. MOEFA found provided but not functional.
4. Exit signage's found removed at some places.

In view of the above shortcomings, the application for renewal of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/ Occupier of Movie Time Cinema Hall.

Yours faithfully,

(Atul Garg)  
Director

*[Handwritten signature]*  
8/9/24

Copy to :-

1. The Section Officer, Licensing Branch (HQ), Office of the Divisional Commissioner (Revenue), GNCTD, 05, Shyam Nath Marg, Delhi- 110054.