

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001

No.F6/DFS/MS/SZ/2024/ G4 | 526

Dated: 28/08/2024

To

The Addl. Commissioner of Police,
 Licensing Unit 1st Floor,
 P.S Defence Colony,
 New Delhi-110049

Subject: - Renewal of Fire Safety Certificate in r/o M/s O Delhi Guest House Located at 8/32, WEA, Karol Bagh, New Delhi-110005.

Sir,

Please refer to online application No. 202408011986, dated 01/08/2024 on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by the officer concerned from this department on 22/08/2024 in the presence of Sh. Akram (Manager) from fire safety point of view.

During the course of inspection following shortcomings are observed:

1. Fire Check Doors found not provided.
2. CO Detectors found not provided.
3. Terrace pump of capacity 900 lpm found nonfunctional on auto mode.
4. Communication system in lif car found nonfunctional.
5. Basement found closed could not be inspected.
6. Atrium found covered and not shown in the plan loaded at MHA portel.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered. The applicant is directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully


 (Atul Garg)
 Director
 Delhi Fire Service
 ok h 

Copy to: - The Manager, M/s O Delhi Guest House Located at 8/32, WEA, Karol Bagh, New Delhi-110005.

2- Executive Engineer Bldg, MCD Civic Centre Minla Road New Delhi to check the occupancy of the basement.