

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/2024/ 495

Dated: 03/09/2024

To

The Assistant Engineer (E)-I,
Parliament Annexe Electrical Works Division CPWD,
Parliament Annexe Extension Building, New Delhi.

Subject:- Regarding Renewal of FSC in r/o Parliament House Annexe building (block A & B),
Parliament House Complex, New Delhi.

Sir,

This has a reference of your letter No. 23(Misc.)AE/E-I/CPWD/2024-25/63 dated 03.08.2024, on the subject noted above. In this regard it is to inform you that the site was inspected by the officers of this department on 21/08/2024 in your presence of Sh. Sanjay Kumar, AE(E), Sh. Amit Kumar, JE(E) the following shortcoming were observed.

1. Detectors found not functional at some floor and not provided at AHU room.
2. Pressurization system found nonfunctional at staircase & lobby.
3. Lift signages found removed and fireman switch found nonfunctional.
4. Smoke management system found nonfunctional in 'A' Block basement.

In view of above, the case is rejected for renewal with a request to rectify the above shortcomings at the earliest for further consideration in the matter.

Yours faithfully,


(Anil Garg)
DIRECTOR
Delhi Fire Service

Copy to :-

1. The Executive Engineer (Elect.) PAEWD, CPWD, 36 GRG Road, New Delhi.
2. Deputy Secretary, Lok Sabha Secretariat, Parliament House Annexe, New Delhi.