



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/SZ/2024/ 491

Dated: 02/09/2024

To

Sh. P. Hrishikesan,
Head ARFF, Delhi International Airport Ltd.,
IGI Airport, New Delhi-110037

**Sub: Regarding renewal of Fire Safety Certificate in r/o PTB at Terminal-1, IGI Airport,
New Delhi-110037**

Sir,

This has reference to your letter No. DIAL/ARFF/01/2024/08 Dated 08/08/2024, on the subject cited above. In this connection, it is to inform you that an inspection was conducted by the concerned officers of this department on 09/08/2024 to verify the availability & operability of fire protection systems. Sh. Chandar Pal Kundu (Head-FP&S) was present at the time of inspection. During the course of inspection, the shortcomings observed are as below.

1. First-Aid Hose-reels need to be extended in some areas as pointed out.
2. Sprinklers to be extended in left out area in basement & AHU-I room.
3. The exit signage found inadequate in some areas as pointed out.

In view of above shortcomings, the application for renewal of fire safety certificate is rejected. You are requested to rectify the shortcomings under intimation to this department for further action in the matter.

Yours faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Chief Development Officer, DIAL, New Udaan Bhawan, Opposite Terminal-3, IGI Airport, New Delhi-110037