



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

463
7/11
आजादी का
अमृत महोत्सव

No. F6/DFS/MS/EH/SZ/2024/ 369

Dated: 02/09/2024

To

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station,
Defence Colony, New Delhi.

Ref: MHA Online Application ID no. 2024073011888

Sub: Regarding renewal of Fire Safety Certificate in r/o M/s Sagar Ratna (Sagar Ratna Restaurant Pvt. Ltd.) Plot No. H-9/1, B-1, M.C.I.E. Mathura Road, New Delhi.

Sir,

This has reference to the MHA online application ID no. 2024073011888 on the subject cited above. In this context it is informed that the said building was inspected by a team of officers concerned of this department on 22.08.2024 in the presence of Mr. Umesh (Manager) and it was observed that the restaurant is running at ground floor of the building which is comprised of Basement + Upper Ground + 02 upper floors. During the inspection following shortcomings were observed.

1. The clear width of staircase at main exit door shall not be less than 1.50 meters.
2. Hose reels, Down comer systems found non functional.
3. Manual Operated Electrical Fire Alarm (MOEFA) system found non functional.
4. LPG bank must be protected by water spray system.
5. Fire pump found non functional.
6. The main entry glass door shall be replaced by a fire check door and it shall not encroach the landing of the common staircase while opening.
7. Auto starting mechanism of terrace fire pump not provided.

In view of above shortcomings, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Atul Garg)
Director
Delhi Fire Service
22/09/24 M