

d97

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/GH/2024/SZ/ 525
To

Dated: 28/08/2024

The Addl. Commissioner of Police,
Lic/Branch, 1st Floor, P.S Defence Colony
New Delhi 110049.

Sub: Regarding renewal of FSC in r/o M/s Shyama International located at C-5/32,
Safdarjung development Area, New Delhi- 110029.

Sir,

This has reference with **MHA Portal ID 2024072911769 dated 29/07/2024** on the subject cited above. In this connection, the premises have been inspected by officer concerned of this department on 20.08.2024 in the presence of Mr. Umesh Kumar of the Guest House. During the inspection, it was observed that the Guest House is running Ground plus Three Upper Floors. The shortcomings observed are as below:

1. Smoke management system not provided in the building as per clause 7.31 of UBBL-2016
2. Carbon Monoxide detector not provided as per clause 7.31 of UBBL 2016.
3. MOEFA found removed.
4. Fire Fighting pump not on auto mode.

In view of above observation, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall not be allowed in the interest of public safety. The liability of any loss of life and property in case of any eventuality / misshape shall be lies with the owner/ occupier of the building.

Yours faithfully


(ANIL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Dy. Commissioner, (Green Park Zone) Municipal Corporation of Delhi, Green Park, New Delhi 110016 (Email: dyanysz@mcd.org.in) Basement of building is being used for office and storage purpose. MCD bldg department is hereby requested to ensure the use of the building as per BBL/UBBL- 2016.