

c/62

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**

No. F6/DFS/MS/School/2024/SZ/ 576  
To,

NEW DELHI- 110001

Dated: 03/09/2024

The Vice Principal,  
Sri Ram International School,  
Prem Nursery, Gopal Nagar, Najafgarh, New Delhi-110043.

**Sub: - Regarding renewal of "FSC" from fire safety point of view in r/o Sri Ram International School, Prem Nursery, Gopal Nagar, Najafgarh, New Delhi-110043.**

Sir,

Please refer to your letter No. SRIS/2024-25/65 dated 28.06.2024, on the subject cited above. In this connection, it is to inform you that officer concerned of this department inspected the school building on dated 23.08.2024 in the presence of Mrs. Jyoti Kohli (Admin. Officer), to verify the fire safety arrangements in accordance with the rules.

At the time of inspection, it was observed that the school building having three blocks namely A- Block (G+3), B- Block (G+3) & C- Block (G+3 not in use). Therefore, following shortcomings were observed: -

1. Passage connecting blocks each other found blocked by class rooms.
2. Hose reels/hydrant system provided but found not functional.
3. Terrace fire pump of 450 LPM provided but found not functional in auto mode.
4. Exit signage's are found removed.

In view of above, renewal of fire safety certificate cannot be considered at this stage. Therefore, you are suggested to rectify the above said shortcomings under the intimation to this department for further necessary action in the matter and running school in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier.

Yours faithfully

(Amit Garg)

Director

Delhi Fire Service

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

: - for necessary action please.