

c/70

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001**

No.F.6/DFS/MS/SZ/2024/ *Schul/ 592*

Dated: 04/09/2024

To,

The Principal,
Delhi International School
(Great Harsh Educational welfare & Cheritable Society)
Sector – 18, Dwarka Phase – II, New Delhi.

Subject: Renewal of Fire Safety Certificate iro Delhi International School (Great Harsh Educational welfare & Cheritable Society) Located at Sector – 18, Dwarka Phase – II, New Delhi.

Sir,

Please refer to your letter No. DISE/2024-25/50 dated 11/07/2024 on the subject mentioned above. In this connection it is to inform you that the premises was inspected by the officer concerned from this department on 21/08/2024 in the presence of Sh. Naresh Kumar from fire safety point of view.

The following shortcoming was observed during the time of inspection:-

1. Hose reel hose & hydrants found non functional
2. Terrace pump found nonfunctional.
3. Alarm system in lift car found nonfunctional

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered. The applicant is directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully

(Signature)
(Atul Garg)
Director
Delhi Fire Service
o/c

Copy to; - The, Directorate of Education Old Secretariat Delhi – 110054