

No. F6/DFS/MS/Hospital/NDZ/2024/ 502

Dated 04 09 2024

To,

The Executive Engineer,
HMED (East), PWD,
GTB Hospital Complex,
Shahdara, Delhi - 110095.

Subject: - Regarding grant of Fire Safety Certificate in r/o Institute of Human Behavior & Allied Science, (IHBAS Hospital) located at Dilshad Garden, Delhi – 110095.

Sir,

This has a reference to your Outdoor Diary No. 4596 dated 26/07/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 27/08/2024 in the presence of Mr. C.L Meena (A.E/PWD) and observed that building comprised of ground plus two upper floors only.

Following shortcomings were observed during time of inspection:

1. First –Aid Hose reels provided but not functional.
2. Internal Hydrants provided but not functional.
3. Yard Hydrants provided but not functional.
4. All fire Pump provided but not functional.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

ok DELHI FIRE SERVICE
@

Copy to: -

1. The Medical Superintendent, Nursing Homes, Directorate General of Health Services, Govt. of NCT of Delhi, 3rd floor, Delhi Govt. Dispensary Building, S-1, School Block, Shakarpur, Delhi - 110032.