



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/2024/SZ/College/285

Dated: 04/09/2024

To

Prof. Sandra Joseph (Principal),
Jesus and Mary College,
Chanakya Puri, New Delhi-110021

Sub: Regarding renewal of Fire Safety Certificate in r/o "Jesus and Mary College" Chanakya Puri, New Delhi-110021

Sir,

This has reference to your office letter No. JMC/Admn/Fire (rp)/2024-25 dated 30/07/2024 received through outdoor diary No. 4769 dated 31/07/2024. In this connection, an inspection was carried out by a team concerned officers of this department on dated 21/08/2024 from fire and life safety point of view. Mr. Abhinav Srivastava (Admin) and Mr. Ram Kailash (Care-taker) was present at the time of inspection. During the course of inspection, the shortcomings observed are as below.

1. Manually operated fire alarm found broken/non-functional in MP Hall/Audi.
2. Automatic fire detectors not provided in MP Hall/Audi, also hydrant point is quite away.
3. Wooden material shall be painted with fire retardant paint.
4. Electrical panel installed under the stairs/escape route shall be covered adequately to prevent any possibility of electrocution or it may be shifted to safer place.
5. Fire/Smoke check doors not provided in canteen area.
6. Hose-reel hoses in bad condition/non-functional, not provided near Canteen.
7. LPG Cylinder found used in Canteen.
8. Entry/exit found encroached with material in Canteen.
9. Lift & exit signage found removed at some locations.
10. Internal & Yard hydrants found in bad condition/non-functional.
11. Fire pumps provided found non-functional.
12. Classes and laboratory running in basement shall be got approved from the authority concerned and copy be provided to this department.

In view of the above shortcomings, the application for renewal of fire safety certificate is rejected. The occupancy of the building/premises in the absence of requisite fire & lift safety measures shall be at the risk and liability of the college management. You are requested to rectify the above shortcomings under intimation to this department for further action in the matter.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to: -

1. The Chief Architect, Department of Architecture & Environs, N.D.M.C. Palika Kendra, New Delhi-110001