



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

d16

No: F.6/DFS/MS/School/2024/WZ/ 594

Dated: 04/09/2024

To,

The Principal,
M.C. Primary School,
J, K, L, M, Block, J.J. Colony,
Bawana, Delhi-110039.

Sub: - Regarding issuance of Fire Safety Certificate in r/o M.C. Primary School, J, K, L, M, Block, J.J. Colony, Bawana, Delhi- 110039.

Sir,

This has reference to your email id dated 06.08.2024 & 13.08.2024 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 23.08.2024 to see the to see the compliance of the requisite fire safety measures. Sh. Sanjay Kumar (In-charge) was present at the time of inspection.

During the course of inspection it was observed that school building is comprised of Ground plus Three upper floors. Your request for issuance of FSC is rejected due to the following shortcomings:-

1. There is only 01 staircase provided against the required 02 staircases up to the terrace having width 1.5 m each.
2. Five numbers of fire extinguishers are required but not provided.
3. Terrace level pump should be in auto mode.
4. Overhead tank of 6000 ltrs also connected with domestic line is provided against the required capacity of 10,000 ltrs exclusively for fire fighting pimp.
5. Exit signage's are not provided.
6. Electrical meter and panel installed under the staircase has to be removed to a safer place.

You are advised to rectify the above-mentioned shortcomings under intimation to this department.

Yours Faithfully

(Atul Garg)
Director

Ph. 011-23414000

Copy to:-

1. Director of Education, MCD, Civic Centre, New Delhi.