



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No: F.6/DFS/MS/2024/WZ/565

Dated: 28/08/2024

To,

The Executive Engineer (Bldg.),  
Delhi Municipal Corporation,  
9<sup>th</sup> Floor, Civic Center, JLN Road,  
New Delhi- 110002.

Sub: - Regarding issuance of Fire Safety Certificate in r/o Educational Building at Property  
Middle School, located at SD & QD Block, Pitampura, Delhi- 110034.

Sir,

This has reference to online portal ID No. 10102221 dated 16/08/2024 on the subject cited above. In this connection, it is to inform you that the joint site inspection of above said educational building has been carried out by the officers concerned of this department on 20.08.2024 to see the compliance of shortcomings issued by this department vide letter No. F6/DFS/MS/BP/2024/WZ/307 dated 04/06/2024. Sh. S.K. Gupta (A.E. MCD) & Sh. Harish Nagpal (Manager) were present at the time of joint site inspection.

During the course of inspection it was observed that the building comprised of Basements, Ground & 04 upper floors. Your request for issuance of FSC is rejected as the following shortcoming was observed:

1. 04 Staircases are provided instead of 05 Nos. in upper floors.

Keeping in view of above shortcoming Fire Safety Certificate is not considered at this stage and rejected. You are advised to rectify the above-mentioned shortcomings for further consideration in this matter.

Yours Faithfully

(Atul Garg)

Director

Ph. 011-23414000

ole R 4

22/8