



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी का
अमृत महोत्सव

No. F6/DFS/MS/Industrial/NDZ/2024/ 501

Dated 04/09/2024

To,

Mr. Ram Prakash (Manager),
Plot no. 97, F.I.E.,
Patparganj Industrial Area,
Delhi - 110092.

Sub: - Regarding grant of Fire Safety Certificate in r/o Plot no. 97, F.I.E located at Patparganj Industrial Area, Delhi - 110094.

Sir,

This has a reference to your outdoor Diary No. 4713 dated 30/07/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 27/08/2024 in the presence of Mr. Ram Prakash (Manager) and observed that building comprised of basement, ground plus three upper floors only.

Following shortcomings were observed during time of inspection:

1. A single staircase of 1.03 meter width is provided against the requirement of two staircase of width 1.50 meter each
2. Fire check door not provided.
3. Exhaust fan not provided in basement & upper floor.
4. First-aid-Hose Reels provided but not functional.
5. MOEFA provided but not functional.
6. Automatic Sprinkler System provided but not functional.
7. Internal Hydrants provided but not functional.
8. Fire pump of 900 LPM provided but not functional.
9. Overhead tank of 6,000 liters capacity is provided against the requirement of 20,000 liters.
10. Exit & floors Signage's not provided in strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

1. The Commissioner, Municipal Corporation of Delhi, 419 Udyog Sadan, Patparganj Industrial Area, Delhi - 110092.