



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

203  
7/2  
आजादी का  
अमृत महोत्सव

No.F6/DFS/MS/School/SZ/2024/ 595

Dated: 04/09/2024

To

The Principal,  
Sky High Modern School,  
1035, Bazar Mohalla, Tughlakabad Village,  
New Delhi-44.

**Sub:-** Regarding issuance of Fire Safety Certificate in r/o Sky High Modern School located at 1035, Bazar Mohalla, Tughlakabad Village, New Delhi-44.

Sir,

With reference to the letter bearing outdoor diary no. 4967 dated 06.08.2024 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 02.09.2024 in the presence of Mr. Tarun (Owner's) and it was observed that the school building is comprised of Ground + 2 upper floors. During the inspection following shortcomings were observed:-

1. One staircase 1.50 meters width not provided in the building.
2. First aid hose reels found not provided.
3. Fire pump having capacity 450 LPM with 40 m head found not provided.
4. Terrace water tank of 10,000 liters found not provided (exclusively for firefighting).
5. Exit signages not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

02/9/24 W

**Copy to:-**

1. The Directorate of Education, Center Zone: Lajpat Nagar, New Delhi-110024.