



75  
Azadi Ka  
Amrit Mahotsav

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/School/2024/SZ/ 591

Dated: 04/09/2024

To

The Manager,  
Vaidik World School,  
Plot No. 310/3, Bijwasan,  
New Delhi-110061

Sub: **Regarding grant of Fire Safety Certificate in r/o Vaidik World School located at Plot No. 310/3, Bijwasan, New Delhi-110061**

Sir,

This has reference to your letter received through outdoor diary No. 5156 dated 12/08/2024. In this connection, the said school premises was inspected by the officer concerned of this department on 28/08/2024 from fire & life safety point of view in your presence. During the course of inspection, the shortcomings observed are as below.

1. Width of single staircase provided is less than the required clear width of 1.50 meter
2. A first-aid hose reel containing 20mm diameter rubber tubing mounted on a revolving drum, directly connected to over-head water storage tank through proper boosting arrangement, terminating into 5mm shut-off nozzle not provided, same shall be required on each floor.
3. A terrace level fire pump of 450 LPM discharge capacity with 40m head and automatic in operation not provided, same shall be required.
4. An overhead water storage tank of 10,000 liters capacity exclusively for fire-fighting not found provided, same shall be required.
5. The exit signage in escape route not provided, same shall be required on each floor at conspicuous locations.

In view of the above, application for issuance of Fire Safety Certificate is rejected. The occupancy of the building/premises in the absence of requisite fire protection measures shall be at risk and responsibility of owner/occupier. You are advised to comply with the observations above for further action in the matter.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054