

d/92

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001

No.F6/DFS/MS/SZ/2024/ 551

Dated: 04/09/2024

To

The Addl. Commissioner of Police,
Licensing Unit 1st Floor,
P.S Defence Colony,
New Delhi-110049

**Subject: - Renewal of Fire Safety Certificate in r/o M/s Guest House Mid Town,
Located at 17A/7, WEA, Karol Bagh, New Delhi-110005.**

Sir,

Please refer to letter No. 1218/Joint CP/Loc. (H), dated 29/07/2024 on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by the officer concerned from this department on 12/08/2024 in the presence of Sh. Rajender Singh (Manager) from fire safety point of view.

During the course of inspection following shortcomings are observed:

1. CO Detectors found nonfunctional.
2. MOEFA and PA system found nonfunctional.
3. Hall seen at Ground floor must be segregated by Fire Check Doors.

In view of the above shortcomings the Fire Safety Certificate from fire safety point of view issued vide this office letter No. F6/DFS/MS/GH/SZ/2022/497, dated 02/11/22 is suspended immediately. The owner/occupier may be directed to comply with the above shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully


(Atul Garg)
Director
Delhi Fire Service

Copy to: -

1. The Manager, M/s Guest House Mid Town, Located at 17A/7, WEA, Karol Bagh, New Delhi-110005.
2. The Executive Engineer (Building), MCD, Civic Centre, Minto Road, New Delhi for information w.r.t. the use of the basement.