

c/23

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/SZ/2024 | 599

Dated: 06/09/2024

To,

The Principal,
Happy English Public School,
RZ -G-13, Nanda Block, Mahavir Enclave,
New Delhi - 110045.

Subject: Issuance of Fire Safety Certificate in r/o Happy English Public School, Located at, RZ -G-13, Nanda Block, Mahavir Enclave, New Delhi - 110045.

Sir,


Please refer to your letter No. F6/DFS/MS/2021/24/HEPS dated 23/07/2024 on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by officer concerned of this department on 30/08/2024 in the presence of Sh. R.S Bajwa (Manager) from fire safety point of view.

During course of inspection the following shortcomings are observed:

1. 2nd Floor found being used for school activities without providing fire safety provisions.
2. Exit Signage's found removed at some places.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage. You are requested to comply the abovementioned shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully,


(Atul Garg)
Director
Delhi Fire Service

Copy to:

1. The Directorate of Education Old Secretariat Delhi - 110054

OK  2/9/24