



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



c/04

No.F6/DFS/MS/School/SZ/2024/ 574

Dated: 02/09/2024

To

The Principal,
The Stepping Stone School,
H-268, 25 Ft Road, Jaitpur Extension Part-2,
Badarpur, New Delhi-44.

Sub: Regarding issuance of Fire Safety Certificate in respect of **The Stepping Stone School** located at **H-268, 25 Ft Road, Jaitpur Extension Part-2, Badarpur, New Delhi-44.**

Sir,

This has reference to email dated 27.08.2024 on the subject cited above. In this context it is informed that the said building was inspected by the officer concerned of this department on 27.08.2024 in the presence of Mohd. Saif Khan (Manager) and it was observed that building is comprised of Ground + 01 upper. During the inspection following shortcoming were observed:-

1. Main staircase of 1.5 meters width shall be provided.
2. The main corridor of 1.50 meters width shall be provided.
3. Exit signages found not provided.

In view of above shortcomings, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(Atul Garg)

Director
Delhi Fire Service

27/8/24

Copy to:-

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.