



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No: F.6/DFS/MS/EH//2024/WZ/373

Dated: 02/09/2024

To,

The Joint Commissioner of Police,  
Licensing Unit, 1<sup>st</sup> Floor,  
Police Station, Defence Colony,  
New Delhi.

Sub: - Regarding renewal of Fire Safety Certificate in r/o The Veggie Bites located at B-304, Ground Floor, Saraswati Vihar, Pitampura, Delhi- 110034.

Sir,

This has reference to your online application received through MHA portal vide ID- 2024070510478 dated 21/07/2024 on the subject cited above. In this connection, it is to inform you that the above said assembly building was re-inspected by officer concerned of this department on 13/08/2024 in presence of Sh. Mahesh Sharma. Following shortcoming was observed at the time of inspection.

1. The alternate exit passing through the kitchen shall be segregated with fire check door.

In view of above, the application for renewal of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the building/ premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/ occupier.

Yours Faithfully

(Atul Garg)

Director

Ph. 011-23414000

Copy to:-

1. The Dy. Health Officer, Keshavpuram Zone, A-1, Public Health Department, MCD, Keshavpuram, New Delhi-110035.
2. The owner/ occupier, M/s The Veggie Bites, B- B-304, Ground Floor, Saraswati Vihar, Pitampura, Delhi- 110034
3. MHA Online ID No. 2024070510478.