

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/GH/NDZ/ 554

Dated: 04/09/2024

To,

The Manager,
M/S Ashoka Ocean Guest House,
4587-89, Shora Kothi, Pahar Ganj,
New Delhi.

**Sub: Regarding renewal of FSC in r/o M/S Ashoka Ocean Guest House at 4587-89,
Shora Kothi, Pahar Ganj, New Delhi**

Sir,

This has reference to your online ID No. 2024080512224 dated 05.08.24, on the subject cited above. In this regard, it is to inform you that the site was visited by the officer concerned of this department on dated 22/08/24 in presence of Mr. Ayub Khan and following shortcomings were observed:

1. CO detectors found non functional.
2. Hose reel found nonfunctional.
3. Pump found nonfunctional and not in auto mode provision.

Hence, the case is rejected and Fire Safety Certificate (FSC) cannot be renewed at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter

Yours faithfully,


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to :-

1. The Addl. Commissioner of Police (Lic.) First floor, PS Defense Colony, New Delhi.