

C-27

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F.6/DFS/MS/NDZ/2024/ 517

Dated: 10/09/2024

To,

Sh. Karanjeet Singh Narang,
Bankey Bihari Commodities Pvt. Ltd.
51/6, D.B.G. Road, Karol Bagh, New Delhi.

Sub: - Regarding renewal of fire safety certificate in r/o Bankey Bihari Commodities Pvt. Ltd. 51/6, D.B.G. Road, Karol Bagh, New Delhi.

Sir,

This has a reference to DFS diary no. 4959 dated 06/08/2024, on the subject cited above. In this connection, it is to inform you that the premise was inspected by the officers concerned of this department on 29/08/24 in the presence of Mr. Manjeet Singh and the following shortcomings were observed.

1. Fire Check Doors found removed.
2. Hose reel & hydrant found nonfunctional.
3. Pump found nonfunctional.

In view of above, the case is rejected with a request to rectify the above shortcomings at the earliest for further consideration in the matter.

Yours faithfully

(Atul Garg)
DIRECTOR
Delhi Fire Service