

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/GH/2024/SZ/562

Dated 06/09/2024

To

The Joint Commissioner of Police / Lic-Branch
1st floor, Police Station,
Defence Colony, New Delhi 110049

Sub: - Regarding issuance of fire safety certificate in r/o M/s CABANA HOTEL (A unit of Shree Prema) R-23, Greater Kailash-I New Delhi- 110048

Sir,

This has reference with **MHA Portal ID No 2024080512228 dated 08/08/2024** on the subject cited above. In this connection this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 03/09/2024 in the presence of Mr. Uday (Manager) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

- 1 First aid hose reel provided but found non- functional.
- 2 Automatic sprinkler system provided but found non-functional.
- 3 Terrace level fire fighting pumps provided but found non- functional.
- 4 Exit signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE