

c/55

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2024/512

Dated: 09/09/2024

To,

Sh. Ajay Khatri GM – Fire & Safety,
IGL Bhawan, Plot No. 04, Community Centre,
Sector-09, R.K Puram,
New Delhi - 110022

Subject: Renewal of Fire Safety Certificate in respect of M/s CNG Station (IGL) Located at Sector – 23 B, Phase-II, Dwarka, New Delhi.

Sir,

Please refer to your letter No. IGL/F&S/2024/15/85/1 dated 06/08/2024 on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by the officer concerned from this department on 03/09/2024 in the presence of Md. Hasim (Manager) from fire safety point of view.

During course of inspection the following shortcomings are observed:

1. Water mist foam Trolley found nonfunctional.
2. Portable gas detector (Hand held gas detector) found non functional it must be calibrated.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered. The applicant is directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully



(Atul Garg)
Director

Delhi Fire Service

ok
h
A/1201

Copy to-

1. The Manager, M/s CNG Station (IGL) Located at Sector – 23 B, Phase-II, Dwarka, New Delhi.