



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

du 7
आजादी का
अमृत महोत्सव

No. F6/DFS/MS/WZ/2024/ 609

Dated:- 06/09/2024

To,

The Principal,
Govt. Co-ed. Sr. Sec. School,
Kavita Colony, New Delhi-110041.

Subj.:- Regarding renewal of Fire Safety Certificate in respect of Govt. Co-ed. Sr. Sec. School, located at Kavita Colony, New Delhi-110041.

Sir,

Please refer to your email dated 12/08/2024, on the subject cited above. In this connection, it is to inform you that the above said school building have been re-inspected by the officer concerned of this department on 28/08/2024 in the presence of Sh. Dharmendra (Estate Manager, Morning Shift) & Sh. Ashok (Estate Manager, Evening Shift). During inspection, it has been observed that the school building is comprised of 01 block - Ground + 03 upper floors & 02 blocks - Ground + 01 upper floor. However, the following shortcoming has been observed:-

1. First Aid Hose Reels found non-functional.
2. Terrace pump of 450 lpm found non-functional.
3. Overhead water storage tank could not be checked due to the absence of an inspection ladder.
4. Electrical meters/panels found underneath the staircases of Block comprised of G+03 upper floors same shall be shifted on another safe place or shall be segregated by erecting brick wall.
5. Firefighting & safety arrangements not provided in M.P. Hall. Width of exits are not provided as per NBC Part-IV/UBBL.

In view of the above shortcomings, the application for renewal of Fire safety Certificate cannot be considered at this stage & rejected. You are advised to rectify the above mentioned shortcoming under intimation to this department for taking further necessary action.

Yours faithfully,

(Atul Garg)
Director

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi - 110054.

Handwritten signature and initials of Atul Garg, Director, with date 06/09/24 and other markings.