



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/Hospital/NDZ/2024/518

Dated: /0/09/2024

To,
The Assistant Engineer (E),
Elect, Maint Division M 2522,
Dr. Hedgewar Arogya Sansthan, Karkardooma,
Delhi.

**Subject: - Regarding grant of Fire Safety Certificate in r/o Health Centre Cum Maternity
Hospital, Kanti Nagar, Delhi**

Sir,

This has a reference to your outdoor dairy no. 5102 dated 09/08/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 30/08/2024 in the presence of Mr. Pursottam (Junior Engineer) and observed that building comprised of ground plus three upper floors.

1. Fire check door found removed.
2. First-aid-Hose Reels provided but not functional.
3. Automatic Sprinkler System provided but not functional
4. MOEFA provided but not functional.
5. Internal Hydrants provided but not functional.
6. Yard Hydrants provided but not functional.
7. All Fire pumps provided but not functional.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Medical Superintendent, Health Centre Cum Maternity Hospital, Kanti Nagar, Delhi.