

c/25

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI- 110001

No. F6/DFS/MS/School/2024/SZ/ 601

Dated: 06/09/2024

To,

The Manager,
Mata Kasturi Devi Sr. Sec. Public School,
Gopal Nagar, Najafgarh, New Delhi- 110043.

Sub: - Regarding renewal of "FSC" from fire safety point of view in r/o Mata Kasturi Devi Sr. Sec. Public School located at Gopal Nagar, Najafgarh, New Delhi-110043.

Sir,

Please refer to your letter No. Nil dated 27.06.2024, on the subject cited above. In this connection, it is to inform you that officer concerned of this department inspected the school building on dated 23.08.2024 in the presence of Mrs. Meenakshi Gupta (Teacher), to verify the fire safety arrangements in accordance with the rules.

At the time of inspection, it was observed that the school comprised of ground plus two upper floors. Therefore, following shortcomings were observed: -

1. Second staircase having width of 1.0m found blocked & width should be increased to 1.35 m.
2. Hose reels/hydrant system provided but found not functional.
3. Terrace fire pump of 450 LPM provided but found not functional.
4. Exit signage's are found removed.

In view of above, renewal of fire safety certificate cannot be considered at this stage. Therefore, you are suggested to rectify the above said shortcomings under the intimation to this department for further necessary action in the matter and running school in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier.

Yours faithfully

(Atul Garg)
Director

Delhi Fire Service

Copy to: -

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

: - for necessary action please.