



No. F6/DFS/MS/Hospital/NDZ/2024/ 20

Dated: 10/09/2024

To,

The Director,  
M/s Monga Medical Centre  
Plot No. J - 10, Krishna Nagar,  
Delhi - 110051.

**Subject: - Regarding grant of Fire Safety Certificate in r/o M/s Monga Medical Centre located at Plot No. J - 10, Krishna Nagar, Delhi - 110051.**

Sir,

This has a reference to your outdoor dairy no. 4030 dated 10/07/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 23/07/2024 in the presence of Dr. V. K. Monga and observed that building comprised of Basement + stilt (Parking) & Reception + Upper ground plus three upper floors.

**Following shortcomings were observed during time of inspection:**

1. Two staircase of width 2.0 & 1.15 meter are provided instead of required width of 1.50 meter each.
2. Staircases are not segregated on ground floor.
3. Smoke Management System not provided in basement and upper floors.
4. First-Aid-Hose Reel provided but not functional.
5. Internal Hydrants provided but not functional.
6. Pumping Arrangements provided but not functional.
7. Overhead water storage tank capacity 5,000 liters is provided against requirement of 10,000 liters.
8. Exit & floors Signage's not provided at strategic location in the building.
9. Lift is going to basement and lift lobby is required on each floor.
10. Lift Pressurization fans provided but not functional.
11. Lift signage's not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL KARG)  
DIRECTOR

O/C DELHI FIRE SERVICE

Copy to: -

1. The Manager, M/s Monga Medical Centre located at Plot No. J - 10, Krishna Nagar, Delhi - 110051.
2. The Exective Engineer (Bldg), Municipal Corpration of Delhi, Plot no. 419, Patparganj Industrial Area, Delhi -110092.
3. The Medical Superintendent, Nursing Homes, Directorate General of Health Services, Govt. of NCT of Delhi, 3<sup>rd</sup> floor, Delhi Govt. Dispensary Building, S-1, School Block, Shakarpur, Delhi - 110032.