

## GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADOUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2024/School/ 608

Dated: 06/09/2024

To

Mr. Dheeraj Wadhwa (General Secretary) Navjeevan Model Secondary School at Outram Line, G.T.B. Nagar Delhi-110009.

Sub: - Regarding grant of fire safety certificate in r/o Navjeevan Model Secondary School located at Outram Line, G.T.B. Nagar Delhi-110009.

Sir,

Please refer to your letter received through online e-mail dated 14.08.2024 on the subject cited above. In this connection this is to inform you that the above mentioned school premises was inspected by the officer concerned of this department on 29.08.2024 in the presence of Mr. Dheeraj Wadhwa (General Secretary) was also present at site to check the existing fire safety measures & means of escape measures. During inspection it has been observed that the school building is comprised of ground & 02 upper floors only. The observations/ shortcomings made are as under:-

- 1. Only one staircase is continues from ground to terrace level and two staircase continues from ground to second floor only and 2<sup>nd</sup> floor to terrace level iron staircase is found removed at site. The all staircase required continues from ground to terrace level.
- 2. Hose reel hose is provided but not functional and damaged condition.
- 3. Terrace level fire pump provided but found not functional.
- 4. Terrace level fire water tank provided but found empty.
- 5. Standby power supply found removed.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school building is at your own risk & responsibility.

Yours faithfully

Ph:-011-23414000

Copy to:-1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.

