

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/Indl./2024/SZ/ 511
To

Dated: 09/09/2024

The Executive Engineer (Bldg) HQ
Municipal Corporation of Delhi,
9th floor, Civic Center, Minto Road,
New Delhi 110002.

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s Plot no. 32, Block-E, Okhla Industrial Area Phase-II, New Delhi 110020.

Sir,

This has reference with **online ID 10093093 dated 29/08/2024** on the subject cited above. In this connection, it is to inform you that the premise has been inspected by officers concerned of this department on 05.09.2024 in the presence of Mr. R.S Meena JE (Bldg) MCD & Mr. Anil Bansal AE (Bldg) MCD to check the compliance of fire safety arrangements from fire safety point of view and following shortcomings were observed:

1. Pressurization of lift/staircase is not done.
2. The width of exit doors at two staircases at all level is provided 1.20 m against the required width of 1.5 m each.
3. The ramp area in basement has been occupied/ encroached for Industrial activity embroidery work and machinery installation.
4. Ventilation system in basement is not working properly and also need to be integrated with fire alarm system (Auto mode).
5. Automatic detection shall be extended for in left out area of basement.
6. Sprinkler system shall be extended for in left out area of basement.
7. Exit signage not provided at strategic location.

Keeping in view of above, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building/ premise in absence of requisite fire safety certificate shall be at the risk and liability of owner/ occupier. The statutory authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARF)
DIRECTOR

DELHI FIRE SERVICE