

c/21

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI – 110001**

No.F6/DFS/MS/SZ/2024/ 519

Dated: 10/09/2024

To

Sh. Dharam Paul Singla,  
Premises No. 46, Pusa Road, Karol Bagh, New Delhi

**Subject: - Renewal of Fire Safety Certificate in r/o Premises No. 46, Pusa Road, Karol Bagh, New Delhi.**

Sir,

Please refer to Form J, dated nil on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by the officer concerned from this department on 02/09/2024 in the presence of Mr. Sanjay (Electrician) from fire safety point of view.

During the course of inspection following shortcomings are observed:

1. Passage to the 2<sup>nd</sup> stair at upper floors found narrowed/ partially blocked/ obstructed.
2. Open able windows are found replaced with fixed window in one staircase.
3. Exhaust system provided in basement but found nonfunctional on auto mode.
4. MOEFA found nonfunctional.
5. Terrace pump of capacity 900 lpm found removed.
6. Terrace tank of 10000 ltrs capacity found removed
7. Pressurization system in lift shaft & lift lobby found removed.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered. The applicant is directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully

  
(Atul Garg)  
Director

Delhi Fire Service

o/c

  
4/9/24

Copy to: - The Executive Engineer (Building), MCD, Karol Bagh Zone, Anand Parbat, New Delhi.