

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



Dated: 06/09/2024

No. F6/DFS/MS/WZ/2024/ 508
To, .

Sh. B.R. Pasrija,
Executive Director/ PD,
Delhi Metro Rail Corporation Ltd.,
25, Ashoka Road, New Delhi-110001.

Sub: - Inspection report in r/o Property Development (PD) area within Station Box at Netaji Subhash Place Metro Station, Line-1, Delhi- 110034.

Sir,

This has reference to your application no. DMRC/PD/L-1/NSP/SB/PP/7/2024-25/3656 dated 12/08/2024 received through outdoor diary number 5177 dated 12/08/2024 on the subject cited above. In this connection, it is to inform you that the inspection of above said assembly building has been carried out by officer concerned of this department on 29/08/2024 to see the compliance of the requisite fire safety measures. Sh. Arun Kashyap (Fire Safety Officer) was present at the time of inspection.

During the course of inspection it was observed that the PD area is comprised of Ground and Mezzanine floor. Your request for renewal of FSC is rejected as the following shortcomings were observed:

1. Fire check door found replaced with normal door.
2. Smoke Management system found provided but not functional.
3. Detectors found removed at some places.
4. Exit signages found removed at some places.

In view of the above shortcomings, the application for renewal of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the Building/ premises in absence of requisite fire safety arrangements shall be at the risk and liabilities of the Owner/ Occupier.

Yours faithfully,

(Arun Garg)
Director

5/9