

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/GH/NDZ/ 571

Dated: 9 / 9/2024

To,

The Manager, M/S Suvidha Tourist Lodge Guest House, 3418-21, Hari Mandir Marg, Pahar Ganj, New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Suvidha Tourist Lodge Guest House, 3418-21, Hari Mandir Marg, Pahar Ganj, New Delhi.

Sir,

This has reference to on line ID No. 2024081412689 dated 14/08/24, on the subject cited above. In this regard, it is to inform you that the site was visited by the officer concerned of this department on dated 30/08/24 in presence of Mr. Praveen Chabara and following shortcomings were observed.

- 1. Co detectors found nonfunctional.
- 2. One room is shown on the ground floor in the building plan whereas in online application form two room are mentioned. Therefore, application needs to be corrected.

In view of above, the case is rejected and FSC cannot be renewed till the compliance of shortcomings as noted above.

Yours faithfully

(Aydı Garg) DİRECTOR Delhi Fire Service

عليل

Copy to:-

- 1. The Commissioner, MCD, Civic Centre, New Delhi
- 2. The Addl. Commissioner of Police (Lic.) First floor, PS Defense Colony, New Delhi.