

C/43

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F6/DFS/MS/GH/NDZ/ 568

Dated: 09/09/2024

To,

The Manager,  
M/S Twenty Twenty Guest House,  
3972-76, Kaseruwalan, Pahar Ganj,  
New Delhi.

**Sub: Regarding renewal of FSC in r/o M/S Twenty Twenty Guest House, located at 3972-76, Kaseruwalan, Pahar Ganj, New Delhi.**

Sir,

This has reference to your online ID No. 2024071210934 dated 16.08.2024, on the subject cited above. In this regard, it is to inform you that the site was visited by the officer concerned of this department on dated 30/08/24 in presence of Mr. Puranchand and following shortcomings were observed:

1. Smoke management system is not provided
2. CO detectors are not provided.
3. Hose reel found non functional.
4. PA system found non functional.

Hence, the case is rejected and Fire Safety Certificate (FSC) cannot be renewed at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter

Yours faithfully,

(Atul Garg)  
DIRECTOR  
Delhi Fire Service

Copy to :-

1. The Addl. Commissioner of Police (Lic.) First floor, PS Defense Colony, New Delhi.