



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No.F6/DFS/MS/GH/SZ/2024/553

Dated: 04/09/2024

C/65

To

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station,
Defence Colony, New Delhi.

Sub:- Regarding issuance of Fire Safety Certificate in r/o M/s Yash Guest House located at Plot no. 34, Nangli Razapur Nizamuddin East, New Delhi-110013.

With reference to the MHA online application ID no. 2024071010801 on the subject cited above, it is informed that the building was inspected by Assistant Divisional Officer (M. Road) from this department on 28.08.2024 in the presence of Mr. Yashpal (Owner) and it was observed that the guest house is running at Ground + 02 upper floors of the building is comprised of Ground + 3 upper floors. During the inspection following shortcomings were observed:-

1. Hose reels found non functional.
2. CO detectors not provided as per required in Gazette Notification dated 27.05.2019, clause 7.31. (viii), UBBL 2016.
3. Fire pump found non functional.
4. Ext signages found not provided.

In view of above shortcomings, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)

Director
Delhi Fire Service

29/8/24 NJ