



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2024/ CC /297

Dated: 12/09/2024

To

Mr. Alok Kr. Ranjan (Director)
 Plot No. D-1, First Floor, Virat Bhawan,
 Commercial Complex, Mukharjee Nagar, Delhi-09.

Sub: - Need confirmation if there are any additional permissions or approval required to run classes (Ambition Law Institute).

Sir,

Please refer to your letter received through e-mail dated 22.07.2024 & 05.08.2024 on the subject cited above. In this connection this is to inform you the above mentioned site was visited by the officer concerned of this department on 07.09.2023 to verify the fire safety arrangements installed in the building. At the time of inspection Sh. Abhishek (Manager) was also present at site. During the course of the inspection it is observed that the building is comprised of basement, ground, mezz & 03upper floors, but coaching centre running at first floor with room no-106, 107 & 108 only. Your request for FSC is rejected under Rule 37 (3) due to following shortcomings.

1. There is 02 nos. of staircase provided having width of 1.30m & 90cm against the requirement of 1.50m each and both staircases shall continues from ground to terrace level.
2. The width of corridor provided is 1.20m against the requirement of 1.50m
3. The width of classroom doors provided is 01m against the requirement of 1.20m.

You are requested to submit sanctioned building plan or as built plan duly signed by registered architect and owner of the above building and rectify above mentioned shortcomings under intimation to this department failing which action will be initiated as per Delhi fire Service Act 2007 & Rules 2010. Till the compliance of shortcomings coaching centre shall not be allowed to operate & management will be held responsible for any loss of life & property.

Yours faithfully

(Atul Garg)
 Director

Ph.-011-23414000

Copy to:-

1. The Commissioner, Municipal Corporation of Delhi, Dr. S.P.M. Civic Centre, 9th Floor, Minto Road, New Delhi-110002:- to take necessary action as deemed fir being the competent authority.